

SOUTH PLACER MUNICIPAL UTILITY DISTRICT

ORDINANCE NO. 87-1

AN ORDINANCE AMENDING ORDINANCE 82-1
RELATING TO SEWER CAPACITY STANDARDS

BE IT ORDAINED BY THE BOARD OF DIRECTORS OF SOUTH PLACER
MUNICIPAL UTILITY DISTRICT AS FOLLOWS:

Section 1

Paragraph C of Subsection 3-04 of Section 3 of the document described in Section 1 of Ordinance 82-1 is hereby amended to read as follows:

C. Capacity - Pipe capacity, in all cases, shall be adequate to carry design flow from the entire tributary area, even if said area is not within the project boundaries. Structures, tanks, wet wells or other facilities used to provide storage of sewage, peak flows or otherwise are prohibited.

No sewer plan in which proposed design flows exceed pipeline peak flow capacity will be approved.

The maximum depth of flow at design conditions in any lateral (10-inch diameter or less) shall be 0.7 diameter. Trunk lines (12-inch diameter or larger) may be designed to flow full unless direct service sewer connections to the trunk are planned and approved, in which case the 0.7 diameter maximum depth shall govern.

Section 2

This Ordinance shall be in effect from and after the date of its final passage.

This Ordinance was introduced on motion of Director Hebard, seconded by Director Lemos, and carried unanimously at a regular meeting of the Board of Directors of SOUTH PLACER MUNICIPAL UTILITY DISTRICT on the 7th day of May, 1987.


This Ordinance was passed at a regular meeting of the Board of Directors of SOUTH PLACER MUNICIPAL UTILITY DISTRICT held on the 4th day of June, 1987, by the following vote:

AYES : Directors: Forristall, Hebard, Lemos, Scheible, Shearer
NOES : NONE
ABSENT: NONE

SOUTH PLACER MUNICIPAL UTILITY
DISTRICT

By: 
JAMES C. FORRISTALL, President

ATTEST:


CAROL BEAN, Secretary